

***Annual Drinking Water Quality Report for 2017***  
***Country Acres Mobile Home Park***  
***315 Stone Church Road, Ballston Spa, New York 12020***  
***Public Water Supply ID #4501795***

**INTRODUCTION**

To comply with State regulations, Country Acres Mobile Home Park will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact Mr. Jeff Pugh, Water System Operator at (518) 316-1389. We want you to be informed about your drinking water. If you want to learn more, please discuss any drinking water issues with him in person.

**WHERE DOES OUR WATER COME FROM?**

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include: microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Departments and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water system serves approximately 125 people through 54 service connections. Our water source is groundwater from one driven well located in the park. The water is chlorinated prior to distribution.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential for contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected, if any. The source water assessments provide resource managers with additional information for protecting source waters into the future.

The source water assessment has rated our water source as having an elevated susceptibility to microbial, nitrate and industrial contamination. These ratings are due primarily to the residential land use and associated activities in the assessment, such as fertilizing lawns. In addition, the well draws from fractured bedrock and the overlying soils may not provide adequate protection from potential contamination. While the source water assessment rates our well as being susceptible to microbials, please note that our water is disinfected to ensure that the finished water delivered into your home meets New York State's drinking water standards for microbial contamination.

The State Health Departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning and education programs. A copy of the assessment can be obtained by contacting us, as noted above.

**ARE THEIR CONTAMINANTS IN OUR DRINKING WATER?**

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include: total coliform bacteria, inorganic compounds, nitrate, nitrite, lead and copper, volatile organic compounds, radiological contaminants and synthetic organic compounds. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one-year-old.

It should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health, Glens Falls Regional Office at (518) 793-3893.

**Table of Detected Contaminants**

Contaminant	Violation Yes/No	Date of Sample	Level Detected (Avg/Max) (Range)	Unit of Measure	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
<b>Inorganic Contaminants</b>							
Barium	No	9/29/15	548	µg/L	2000	MCL = 2000 µg/L	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Chloride	No	10/05/17	71.9	mg/L	N/A	MCL = 250 mg/L	Naturally occurring or indicative of road salt contamination.
Nitrate (as Nitrogen)	No	10/05/17	0.02	mg/L	10	MCL = 10 mg/L	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Manganese	No	10/05/17	0.01	mg/L	N/A	MCL = 0.3 mg/L	Naturally occurring; Indicative of landfill contamination.
Sodium	No	10/05/17	12.5	mg/L	N/A	See Note 1	Naturally occurring; Road salt; Water softeners; Animal waste
Sulfate	No	10/05/17	15.9	mg/L	N/A	MCL = 250 mg/L	Naturally occurring
Zinc	No	10/05/17	8.72	µg/L	N/A	MCL = 5.0 mg/L	Naturally occurring; Mining waste.
Color	No	10/05/17	5	CU	N/A	MCL = 15 Units	Large quantities of organic chemicals, inadequate treatment, high disinfectant demand and the potential for production of excess amounts of disinfectant byproducts such as trihalomethanes, the presence of metals such as copper, iron and manganese; Natural color may be caused by decaying leaves, plants, and soil organic matter.
Odor	No	10/05/17	1	TON	N/A	MCL = 3 Units	Organic or inorganic pollutants originating from municipal and industrial waste discharges; natural sources.
<b>Radiological</b>							
Gross Alpha	No	3/10/08	1.7	pCi/L	0	MCL = 15	Erosion of natural deposits

**NOTES:**

1. Water containing more than 20 mg/l of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/l of sodium should not be used for drinking by people on moderately restricted sodium diets.

**DEFINITIONS:**

**Action Level (AL):** The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

**Maximum Contaminant Level (MCL):** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

**Maximum Contaminant Level Goal (MCLG):** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

**Maximum Residual Disinfectant Level (MRDL):** The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

**Maximum Residual Disinfectant Level Goal (MRDLG):** The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

**Micrograms per liter (µg/L):** Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

**Milligrams per liter (mg/L):** Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

**Millirems per year (mrem/yr):** A measure of radiation absorbed by the body.

**Non-Detects (ND):** Laboratory analysis indicates that the constituent is not present.

**Picocuries per liter (pCi/L):** A measure of the radioactivity in water.

**Treatment Technique (TT):** A required process intended to reduce the level of a contaminant in drinking water.

#### **WHAT DOES THIS INFORMATION MEAN?**

As you can see by the table, our system had no MCL violations in 2017. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

#### **IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?**

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

#### **INFORMATION ABOUT LEAD IN DRINKING WATER AND ITS EFFECT ON CHILDREN:**

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Country Acres Mobile Home Park is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

#### **DO I NEED TO TAKE SPECIAL PRECAUTIONS?**

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

#### **WHY SAVE WATER AND HOW TO AVOID WASTING IT?**

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- ◆ Saving water saves energy and some of the costs associated with both of these necessities of life;
- ◆ Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- ◆ Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- ◆ Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- ◆ Turn off the tap when brushing your teeth.
- ◆ Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it up and you can save almost 6,000 gallons per year.
- ◆ Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- ◆ Install water-saving showerheads or flow restrictors. This can save 700 gallons per month.
- ◆ Shorten your showers. Even a one or two-minute reduction can save up to 700 gallons per month.
- ◆ Capture tap water, while waiting for hot water to come down the pipes, in a watering can to use later on house plants or your garden. Saves 200 to 300 gallons per month.

#### **CLOSING**

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. Please call our office if you have questions.

This report was prepared for the Country Acres Mobile Home Park by:  
CNA Environmental, LLC  
27 Kent Street, Suite 102,  
Ballston Spa, New York 12020  
(518) 884-0800

